

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**



**LISTING No.** 3240-1483:171

Page 1 of 1

**CATEGORY:** Duct Smoke Detector Housing/Base

**LISTEE:** Mirtone, 8985 Town Center Parkway, Bradenton, FL 34202  
Contact: Jewell Micochero (941) 739-4358 FAX (941) 308-8123

**DESIGN:** Models SD-CJ and SD-CT duct smoke detector subassembly (controller). Intended to detect an abnormal amount of smoke density in the return air ducts of air conditioning and ventilating systems. Model SD-4WJ is composed of Model SD-ST or Model SD-SJ (CSFM Listing No. 3242-1501:153) duct detector (sensor). Refer to the listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as duct smoke detectors for used with separately listed compatible fire alarm control units in conjunction with Models SD-SJ or SD-ST series (CSFM Listing No. 3242-1501:153) duct smoke detector controller. Refer to listee's Installation Instruction Manual for details.

**XL:** 3240-1591:225

11-03-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 28, 2008**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*